






MicroTech[®] Chiller System Controller



For Use with McQuay Models PEH, PFH, ALR, WHR, ALS & PFS

Contents

Introduction	4	Field Wiring	17
Applying the CSC	5	Power	17
General Description	8	Network Communications	17
Component Data	8	PC Connection	19
Microprocessor Control Board	9	Analog Inputs	20
Output Board	10	Digital Inputs	21
Input Conditioning Module Terminal Board	10	Analog Outputs	23
Snap Track	10	Digital Outputs	25
Keypad/Display Interface	11	Network Commissioning	25
Software ID	12	Addressing the Controllers	25
Software Compatibility	12	Minimum Controller Setup	26
Accessories	13	Connecting the Communications Trunk	26
Input Conditioning Module	13	Service Information	29
Analog Output Expansion Module	13	Wiring Diagram	29
Solid-State Relay Kit	13	Test Procedures	30
Modem Kit	13	Status LED Diagnostics	30
MicroTech Monitoring and Networking Options	14	Troubleshooting Power Problems	30
PC Monitoring	14	Troubleshooting Communications Problems	31
Network Master Panel	14	Troubleshooting the Keypad/Display Interface	31
Open Protocol	14	Troubleshooting Analog Inputs	32
Installation	15	Troubleshooting Digital Inputs	32
Panel Location and Mounting	15	Troubleshooting Analog Outputs	32
Sensor Installation	16	Troubleshooting Output Boards	33
		Troubleshooting Solid-State Relays	34
		MCB Replacement	35
		Parts List	35

McQuay and MicroTech are registered trademarks of McQuay International.

Monitor and Open Protocol are trademarks of McQuay International.

Microsoft and MS-DOS are registered trademarks of Microsoft Corporation.

IBM is a registered trademark of International Business Machines Corporation.

©1995 McQuay International. All rights reserved throughout the world.

Illustrations

Figures:

1. Typical Simple Chilled Water System	5
2a. Parallel Configurations	5
2b. Series/Parallel Configurations	5
2c. Dual-Compressor Centrifugal Configurations.....	5
2d. Combination Configurations.....	6
2e. Above Configurations with Common Primary Pump ...	6
2f. Above Configurations with Common Primary Pump and Isolation Valves.....	6
3a. Fixed-Speed Secondary Pump	6
3b. Variable-Speed Secondary Pump	6
3c. Lead/Standby Secondary Pumps.....	7
3d. Sequenced Secondary Pumps.....	7
4. Pressure-Controlled Loop Bypass.....	7
5. CSC Layout	8
6. Microprocessor Control Board (MCB)	9
7. Hex Switches.....	10
8. Input Conditioning Module Terminal Board.....	11
9. Keypad/Display Interface	11
10. Software ID Label.....	12
11. Input Conditioning Module (ICM).....	13
12. Analog Output Expansion Module (AOX-4)	13
13. CSC Dimensions	15
14. Immersion Sensor	16
15. Brass Thermowell.....	16
16. CSC Field Wiring Schematic.....	18
17. RS-232 Cable Pinouts for 9-Pin Serial Ports (AMP Connector)	19
18. RS-232 Cable Pinouts for 25-Pin Serial Ports (AMP Connector)	19
19. Cooling Tower Alarm Field Wiring - Fail Status Only.....	22
20. Analog/Digital Input Field Wiring Connections	23
21. Analog Outputs Field Wiring Connections.....	24
22. AMP Connector Terminal Configuration	27
23. CSC Schematic Legend.....	29
24. CSC Schematic.....	29
25. MCB Power Supply Terminals	31
26. Output Board Relay Sockets	33
27. Testing a Typical Relay Circuit.....	34
28. Testing a Relay Circuit with a Disconnection.....	34

Tables:

1. MicroTech Unit Controller Installation Literature	4
2. MicroTech Unit Controller Operation Literature.....	4
3. Model-Specific Chiller Installation Literature.....	4
4. Green and Red Status LED Indication.....	9
5. Amber Status LED Indication.....	9
6. Analog Inputs/Field Wiring Terminal Strip Number ...	10
7. Digital Inputs/Field Wiring Terminal Strip Number	10
8. Program Code CSC1*01A Software Compatibility...	12
9. Accessories Installation Manuals.....	13
10. PC Specification	14
11. CSC Environmental Specifications	15
12. Analog/Digital Inputs and Outputs	20
13. Port B Voltages-AMP Type Connector.....	27
14. Network Communications Field Wiring Terminals	27

Introduction

This manual provides information about the MicroTech® Chiller System Controller (CSC) for McQuay centrifugal (series 100 and 200), reciprocating, and screw chillers. It describes the components, field wiring, network commissioning procedures, and service procedures.

For information about the CSC's features, sequences of operation, and programmable options, refer to Bulletin No. OM 127, *MicroTech Chiller System Controller*. For specific information about the MicroTech chiller controllers, refer to the appropriate MicroTech unit controller installation literature or operation manual (see Tables 1 and 2). For installation and commissioning instructions and general information on a particular unit, refer to its model-specific installation manual (see Table 3).

Table 1. MicroTech Unit Controller Installation Literature

Chiller Type	Bulletin Number
Series 100 Centrifugal	IM 403
Series 200 Centrifugal	IM 616
Reciprocating	IM 493
Screw	IM 549

Table 2. MicroTech Unit Controller Operation Literature

Chiller Type	Bulletin Number
Series 100 Centrifugal	IM 403 & APM 950
Series 200 Centrifugal	OM 125
Reciprocating	IM 493
Screw	IM 549

Table 3. Model-Specific Unit Installation Literature

Chiller Model	Bulletin Number
PEH, PHH	IM 307
ALR (40–195 tons)	IM 499
WHR (40–240 tons)	IM 508
ALS	IM 548
PFS	IM 609

⚠ WARNING

Electric shock hazard. Can cause personal injury or equipment damage.

This equipment must be properly grounded. Connections and service to the MicroTech control panel must be performed only by personnel that are knowledgeable in the operation of the equipment being controlled.

⚠ CAUTION

Static sensitive components. A static discharge while handling electronic circuit boards can cause damage to the components.

Discharge any static electrical charge by touching the bare metal inside the control panel before performing any service work. Never unplug any cables, circuit board terminal blocks, or power plugs while power is applied to the panel.

NOTICE

This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with this instruction manual, may cause interference to radio communications. It has been tested and found to comply with the limits for a Class A digital device, pursuant to part 15 of the FCC rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. Operation of this equipment in a residential area is likely to cause harmful interference in which case the users will be required to correct the interference at their own expense. **McQuay International disclaims any liability resulting from any interference or for the correction thereof.**

Applying the CSC

The CSC has been designed to control several common chiller plant configurations. Figure 1 shows a typical simple chilled water system. Following are descriptions of this typical plant configuration and guidelines for applying the CSC in them. Note that the McQuay chillers in these configurations can be all centrifugal, all reciprocating, all screw, or a combination of centrifugal, reciprocating, or screw.

The CSC may be suitable for applications other than the ones shown. If your application does not match one of the listed configurations, contact your McQuay sales representative for assistance.


Typical Simple Chilled Water System

The typical chilled water system configuration is shown in Figure 1. The characteristics of this system consist of the following: (1) a set of chillers, usually piped in parallel, (2) each chiller has its own primary chilled water pump, (3) the system may or may not have a bypass line and valve that is controlled by a differential pressure controller, (4) the system may or may not have secondary pump(s) to distribute water to the cooling loads.

To see the various configurations available, Figures 2a–2f, Figures 3a–3d, and Figure 4 can be inserted into the typical simple chilled water system shown in Figure 1.

Note: As used throughout this manual, the word *chiller* means chiller in all cases except for dual-compressor centrifugals. For these machines, each *compressor*—along with its associated MicroTech controller—is considered a “chiller.”

Figure 1. Typical Simple Chilled Water System



Chiller Evaporator Configuration

In these systems (Figures 2a through 2d), the temperature of the water entering the loads will always be very close to each chiller's leaving evaporator water temperature setpoint.

Figure 2a. Parallel Configurations




Figure 2b. Series/Parallel Configurations




Figure 2c. Dual-Compressor Centrifugal Configurations






Figure 2d. Combination Configurations




Figures 2e and 2f are the same as the above configurations except (1) all chillers share a common primary pump (Figure 2e) or (2) all chillers share a common primary pump but each chiller has an isolation valve (Figure 2f).

Figure 2e. Above Configurations with Common Primary Pump



In the configuration of Figure 2e, the chilled water supply temperature will be very close to each chiller's leaving evaporator water temperature setpoint if all the chillers are on. If some chillers are on and some are off, the CSC will lower each chiller's leaving evaporator water temperature setpoint to compensate for water mixing.

Figure 2f. Above Configuration with Common Primary Pump and Isolation Valves.



In the configuration of Figure 2f, the chilled water supply temperature will always be very close to each chiller's leaving evaporator water temperature setpoint.

Caution: Significant changes in the chilled water flow rate through the evaporators can result when the chillers in the configuration of Figure 2f are turned on and off. Large flow rate changes can cause erratic chiller control.

Secondary Pump / Decoupler Line Configuration

Figures 3a–3d represent the four secondary pump control options available using the CSC.

Figure 3a. Fixed-Speed Secondary Pump






Figure 3b. Variable-Speed Secondary Pump



Using the variable-speed secondary pump will maintain a desired pressure across the chilled water loop.


Note: A pressure-controlled loop bypass (Figure 4) may not be used in conjunction with a variable-speed secondary pump.

Figure 3c. Lead/Standby Secondary Pumps



Using the lead/standby secondary pumps enables the CSC or the user to select what pump is the lead pump, and what pump is the standby pump. If the lead pump fails, the standby pump starts automatically. The auto-lead feature automatically swaps the lead and standby pumps based on run time.

Figure 3d. Sequenced Secondary Pumps




Using sequenced secondary pumps enables the CSC to turn the chilled water pumps on and off to maintain a constant pressure difference between the secondary supply and return lines.

Note: If a pressure-controlled loop bypass (Figure 4) is used in conjunction with sequenced secondary pumps, only one differential pressure transducer is required.

Loop Bypass Configuration

The CSC will modulate the bypass valve as required to maintain an adjustable differential pressure setpoint. The bypass line and differential pressure sensor shall be installed between the chilled water supply and return lines.

Figure 4. Pressure-Controlled Loop Bypass



General Description

The **MicroTech®** Chiller System Controller (CSC) is a micro-processor-based controller that provides sophisticated monitoring and control capabilities to McQuay chillers. The CSC is designed to monitor and control up to four dual-compressor centrifugal chillers, up to eight single-compressor centrifugal chillers, up to eight non-centrifugal chillers (reciprocating and screw), or any combination that results in eight or fewer unit controllers.

The CSC's design offers full input and output flexibility. The base panel is equipped with an Input Conditioning Module (ICM) that can condition eight analog and eight digital inputs, and keypad/display that provides a user interface to the control panel for the monitoring and control of attached chillers.

The CSC also has accessories that can increase the number of inputs and outputs. Up to two more ICMs can be purchased, increasing the number of analog and digital

inputs to 24. Up to three Analog Output Expansion Modules (AOX-4) can be purchased, providing twelve analog outputs. A relay kit is an option that can add eight digital outputs. Each relay kit is equipped with eight AC power rated relays. The relays are plugged into the Output Board (OB). Up to three relay kits can be ordered for a total of 24 digital outputs.

The CSC is capable of performing all network communications required for complete chiller system control. If desired, it can be incorporated into a MicroTech network that includes a Network Master Panel (NMP) and other MicroTech controllers. In either case, an IBM® compatible computer containing MicroTech Monitor™ software can be connected to give you full-screen monitoring and control capability. The computer can be connected directly or remotely via telephone lines with an optional modem.


Component Data

Figure 5 shows the control panel layout for the CSC. The main components of the controller are the Microprocessor Control Board (MCB), the Output Board (OB), the Input Conditioning Module (ICM) Terminal Board, and the Keypad/Display Interface (KDI). All of these major components are mounted inside a standard NEMA 1 enclosure. They

are interconnected by ribbon cables, shielded multi-conductor cables, or discrete wiring. Power for the system is provided by transformers T1 and T2.

Following are descriptions of these MicroTech components and their input and output devices.


Figure 5. CSC Layout



Microprocessor Control Board

The Microprocessor Control Board (MCB) is shown in Figure 6. It contains a microprocessor that is preprogrammed with the software required to monitor and control chillers that are connected to the CSC. The various MCB **connections and components** are described below.

Figure 6. Microprocessor Control Board (MCB)



Digital Inputs Connection

The MCB receives digital inputs from the Input Conditioning Module (ICM) Terminal Board through the Digital Inputs connector via a plug-in ribbon cable. These inputs are conditioned by the ICM. See "Input Conditioning Module (ICM)" in the "Accessories" section of this manual for more information on the ICM.

Analog Inputs Connection

The MCB receives conditioned analog inputs from the Input Conditioning Module (ICM) Terminal Board through the Analog Inputs connector via a plug-in ribbon cable. These inputs are conditioned by the ICM. After having been conditioned, all analog inputs enter the MCB through the Analog Inputs port as 0-5 Vdc signals. See "Input Conditioning Module (ICM)" in the "Accessories" section of this manual for more information on the ICM.

Digital Outputs Connection

After processing all input conditions and network data, the MCB sends the appropriate output signals to output devices through the Digital Outputs port via a plug-in ribbon cable.

Aux/Out Terminal Strip

The Aux/Out terminal strip provides 5 Vdc and 13 Vdc to the CSC field wiring terminal strip. The 5 Vdc powers the back light of the LCD or other auxiliary equipment. The 13 Vdc can be used to power a modem or an Analog Output Expansion Module. See the "Accessories" section of this manual for more information on the modem and Analog Output Expansion Module.

Power In Connector

The MCB receives 18 Vac, center-tapped power from transformer T2 through the Power In connector. This power drives all logic and communications circuitry, the Aux/Out terminal strip, and the Keypad/Display Board. Refer to the panel's wiring diagram or Figure 24 for more information.

Power Fuses

Two identical 2-amp fuses are located to the right of the Power In connector. These fuses are in the MCB power supply circuit.

Microprocessor Status LEDs

The green, red, and amber LEDs on the MCB provide information about the operating status of the microprocessor. The amber LED also indicates the existence of alarm conditions.

Following is the normal start-up sequence that the three status LED's should follow when power is applied to the MCB:

1. The red ("Reset") LED turns on and remains on for approximately 5 seconds. During this period the MCB performs a self-test.
2. The red LED turns off and the green ("Running") LED turns on. This indicates that the microprocessor has passed the self-test and is functioning properly.
3. The amber ("Active") LED remains off continually if no alarm conditions exist in the network. If alarm conditions exist, the amber LED will flash as shown in Table 5.

If the above sequence does not occur after power is applied to the controller, there is a problem with the MCB or its power supply. For more information, refer to the "Test Procedures" section of this manual, which is under "Service Information."

Tables 4 and 5 summarize the green, red, and amber status LED indications.

Table 4. Green and Red Status LED Indication

Green LED State	Red LED State	Indication
Off	Off	No power to MCB
Off	On*	Self-test failure or power supply problem
On	Off	MCB operating normally

* For longer than 5 seconds.

Table 5. Amber Status LED Indication

Amber LED State	Indication
Off	Normal operation
On 1/2 second; Off 1/2 second	Alarm condition

Keypad/LCD Display Connection

The MCB receives input commands and operating parameters from the keypad and sends requested information to the display through the Keypad/LCD Display port via a plug-in ribbon cable.


Hex Switches

The MCB includes two hex (hexadecimal) switches that are used to set the CSC network address.

The HI and LO hex switches are shown in Figure 7. A "hex switch setting" is defined as the HI switch digit followed by the LO switch digit. For example, a hex switch setting of 2F would have the HI switch set to "2" and the LO switch set to "F." Refer to "Addressing the Controllers" in the "Network Commissioning" section of this manual for more information.

Note: You can change the setting of a hex switch with a $\frac{3}{32}$ -inch tip slotted-blade screwdriver. If a hex switch setting is changed, power to the MCB must be cycled in order to enter the new setting into memory. This can be done by turning the panel's power switch off and then back on.

Figure 7. Hex Switches



Expansion Bus Connection

The Expansion Bus connector sends output signals to the Analog Output Expansion Module (see the "Accessories" section) via a ribbon cable. The output signals are used by the Analog Output Expansion Module to drive various control devices.

Communication Ports

The MCB has two communication ports: port A and port B. Each port has six terminals and is set up for both the RS-232C and RS-485 data transmission interface standards. The male and female connectors for these ports are manufactured by AMP. Therefore, they are referred to as "AMP plugs" or "AMP connectors" throughout this manual. Socketed fuses located next to the ports protect the communications drivers from voltage in excess of ± 12 Vdc. Following are brief descriptions of each port's function.

Port A: Port A is for communications with an IBM compatible PC using the RS-232C interface standard. The PC can be directly connected, over a limited distance, with a twisted, shielded pair cable, or it can be remotely connected via phone lines with a modem. Port A can also be used to connect a licensed building automation system to the MicroTech network via Open Protocol. The default communications rate is 9600 baud. For more information, see "PC Connection" in the "Field Wiring" section of this manual.

Port B: Port B is for MicroTech network communications using the RS-485 interface standard. A twisted, shielded pair cable should be connected to port B via terminals B+, B-, and GND on terminal block T11. The communications rate is 9600 baud. For more information, see "Network Communications" in the "Field Wiring" section of this manual.

Output Board

The Output Board (OB) accepts up to 24 digital outputs from the MCB. Each output has fused sockets and can be used to switch AC or DC power by selecting a particular relay output module. Screw terminals allow for field wiring connections to the output device. Each output has an on-board LED that illuminates when an output socket that contains a relay is activated by the MCB. Following are the Output Board's power ratings:

- 120V ~ 50/60 Hz
- 250V ~ 50/60 Hz

Input Conditioning Module Terminal Board

The Input Conditioning Module (ICM) Terminal Board allows the transfer of up to 24 analog and 24 digital conditioned inputs to the MCB. The ICM Terminal Board has three edge card connectors, field wiring terminals for analog and digital inputs, field wiring terminals for 5 Vdc and 24 Vac, field wiring terminals for communication ports, and ribbon cable connections to the MCB.

The ICM Terminal Board edge card connectors accept up to three Input Conditioning Modules (ICM). Each ICM can condition up to eight analog and eight digital input signals. These input signals come from external devices such as room temperature sensors or dry contacts. The signals enter the ICM through the field wiring terminals labeled AI and DI on the ICM terminal board.

Analog Input (AI)

There are three analog input field wiring terminal strips labeled T1, T3, and T5. Each terminal strip has 16 screw terminals. When an analog signal is connected to the terminal strip, the positive (+) wire connects to the even numbered screw terminal and the ground (-) wire connects to the odd numbered screw terminal (see Table 6).

Table 6. Analog input Field Wiring Terminal Strip Numbers

Terminal Strip Number	Screw Terminal Range
T1	100-115
T3	132-147
T5	164-179

Digital input (DI)

There are three digital input field wiring terminal strips labeled T2, T4, T6. Each terminal strip has 16 screw terminals. When a digital signal is connected to the terminal strip, the odd numbered screw terminal sends 24 Vac to the external device. When a contact in the external device closes, the 24 Vac passes through the contact and back through a return wire to the even numbered screw terminal. This return voltage then trips an opto-electric switch allowing the MCB to sense the digital input.

Table 7. Digital Input Field Wiring Terminal Strip Numbers

Terminal Strip Number	Screw Terminal Range
T2	116-131
T4	148-163
T6	180-195

Power

Above each edge card connector are field wiring terminals for 5 Vdc (regulated) and 24 Vac (ground referenced). These terminals can be used to power peripheral devices. The 5 Vdc is also used to power the LEDs in the Output Board.


Communications

Located on the ICM Terminal Board are communications field wiring terminals. Terminals B+, B-, and GND connect to the chiller unit controller's communications field wiring terminals. Terminals A+, A-, and GND connect to an optional PC with MicroTech Monitor™ software.

Snap Track

The snap track is a device used to mount circuit boards, in particular, the AOX-4 board, to the CSC. The snap track is located directly below the Input Conditioning Module (ICM) Terminal Board. Ridges on the top and bottom of the snap track hold the circuit board in place.

Figure 8. Input Conditioning Module Terminal Board



Keypad/Display Interface

The Keypad/Display Interface (KDI) (see Figure 9) gives you a local interface with the CSC. All operating conditions, system alarms, control parameters, and schedules can be monitored from the display. If the password has been entered, any adjustable parameter or schedule can be modified with the keypad. Because the display is backlit, the liquid-crystal characters are highly visible regardless of the ambient light level. You can adjust the display contrast with a small pot located on the back of the board. An Alarm LED and Alarm Horn are also located on the KDI. For information on using the keypad/display, refer to the "Getting Started" portion of Bulletin No. OM 127, *MicroTech Chiller System Controller*.


Alarm LED: The red "Alarm" LED will blink whenever there is an alarm in the CSC or any of the chillers.

Alarm Horn

If it is enabled, the piezo alarm annunciator (Alarm Horn) will sound whenever an alarm occurs in the CSC or any of the chillers. To silence the alarm Horn, press the alarm key on the CSC's keypad. You can also set up the horn so that it sounds only when certain types of alarms occur (Comm Loss, Faults, Problems, or Warnings). For more information, refer to the "Alarm Monitoring" section of Bulletin No. OM 127, *MicroTech Chiller System Controller*.

Note: Silencing the Alarm Horn does not clear an alarm. For more information, refer to the "Alarm Monitoring" section of Bulletin No. OM 127.


Figure 9. Keypad/Display Interface – LED Status Board



Software ID


MicroTech CSC software is factory installed and tested in each panel prior to shipment. The software is identified by a program code (also referred to as the "Ident"), which is printed on a small label affixed to the MCB. An example of this label is shown in Figure x. The program code is also encoded in the controller's memory and is available for display on menu 28 of the keypad/display or a PC equipped with MicroTech **Monitor™** software. Using menu 28 or Monitor software is the most reliable way of determining the controller's program code.

CSC program codification is as follows:



At the time of this writing, the program codes for standard CSC software are CSC1 E01A and CSC1 S01 A. If your CSC software has a later revision code (for example, CSC1 E01 B), some of the information in this manual may be inaccurate. However, since only very minor software changes are considered revisions, any inaccuracies should be insignificant.

Figure 10. Software ID Tag



Software Compatibility

Note that CSC1E01A and CSC1S01A are not compatible with some earlier versions of MicroTech centrifugal, reciprocating, and screw chiller controller standard software. The current software compatibility is summarized in Table x. The wildcard character (*) can be any letter.

If you want to use a CSC with older chillers that have incompatible standard software, the chiller software must be upgraded. (This applies to all series-100 centrifugal chillers.) If you have a version of chiller software that is later than the compatible programs shown in Table x, it is likely that program CSC1 *01* is compatible with it; however, it may not be. To find out for sure, contact McQuayService.

File Names

In all cases, the file names of the compatible programs shown in Table x are the same as the program codes except that they also include a "COD" extension. For example, the file for program PC209A is called "PC209A.COD."

Table 8. Program Code CSC1*01A Software Compatibility

Chiller Controller	Compatible Programs	Incompatible Programs
Series-ZOO Centrifugal	CFG1*01C	CFG1*01A and CFG1*01B
	CFG3*01C	CFG3*01A and CFG3*01B
	CFG5*01C	CFG5*01A and CFG5*01B
Series-100 Centrifugal: Display Proc.	PDR09A	PDR08* and earlier
	PDM09A	PDM08* and earlier
Series-100 Centrifugal: Control Proc.	PC209A	PC208* and earlier
	PC409A	PC408* and earlier
	PC509A	PC508* and earlier
Reciprocating	RCP1*01B	RCP1*01A
	RCP2*01B	RCP2*01A
	none	AWR-*12* and earlier
Screw	SC2-*18D	SC2-*18C and earlier
	SC24*18D	SC24*18C and earlier
	SC3-*18C	SC3-*18B and earlier
	SC34*18C	SC34*18B and earlier

Accessories

The accessories for the CSC allow for additional analog inputs, analog outputs, digital inputs, and digital outputs. The components that make these additional inputs and outputs possible are the Input Conditioning Module (ICM), the Analog Output Expansion Module (AOX-4) and the Solid-State Relay Kit (SSR). The modem kit is an option that allows remote or off-site PC monitoring and control of the CSC when used with Monitor software. See Table 9 for the installation manuals on the different accessories.

Table 9. Accessories Installation Manuals

Accessory	Installation Manual
Input Conditioning Module (ICM)	IM 605
Analog Output Expansion Module (AOX-4)	IM 607
Solid-State Relay Kit (SSR)	IM 606
Modem Kit	IM 564

Input Conditioning Module


The Input Conditioning Module (ICM) (see Figure 11) allows the user to add eight analog and eight digital inputs to the CSC. The ICM is inserted into the edge card connector on the ICM Terminal Board. A maximum of three ICMs can be used on the CSC providing up to 24 analog and 24 digital inputs. An input conditioning switch on the ICM selects what type of analog input is needed.

Following are the four types of analog inputs available:

- 3K Ω thermistor
- 4-20 mA signal (4-wire type)
- 0-5 Vdc signal (1-5 Vdc actual)
- 0-1 0 Vdc signal (2-10 Vdc actual)

The digital inputs must be a dry contact closure. When contact closure is made, an LED on the ICM illuminates indicating which input is active. For more information on the Input Conditioning Module (ICM), see Bulletin No. IM 605, *MicroTech Input Conditioning Module*.

Figure 11. Input Conditioning Module (ICM)




Analog Output Expansion Module

The Analog Output Expansion Module (AOX-4) (see Figure 12) provides variable voltage or current output control signals from the CSC to two different current and voltage ranges. The AOX-4 is inserted into the snap track of the CSC. Up to three AOX-4 boards can be installed providing a maximum of 12 output channels. Jumpers on the AOX-4 allow the user to configure the output ports to one of the following current/voltage selections:

- 0-5 Vdc
- 0-10 Vdc
- 0-5 mA
- 0-20 mA

For more information on the Analog Output Expansion Module, see Bulletin No. IM 607, *MicroTech Analog Output Expansion Module*.

Figure 12. Analog Output Expansion Module (AOX-4)



Solid State Relay Kit

The Solid-State Relay Kit consists of a package of eight AC power rated output relays. The relays plug into the 24-channel Output Board (OB) in the CSC. If other types of relays are needed, such as dry contact or DC power rated, they can be ordered as individual units (see "Parts List"). For more information on the Solid-State Relay Kit, see Bulletin No. IM 606, *MicroTech Solid-State Relay Kit*.

Modem Kit

The Modem Kit allows communications between a MicroTech controller or network of controllers and a remote or off-site PC. The modem kit contains a 14.4K baud rate modem and an interface cable that connects directly to port A of the controller. For more information on the Modem Kit, see Bulletin No. IM 564, *MicroTech Modem Kit*.

MicroTech Monitoring and Networking Options

PC Monitoring

A PC (personal computer) equipped with the appropriate Monitor software can be used to provide a high-level interface with a MicroTech network (see PC specification below). Monitor software features a **Windows™-based** display, multilevel password access, and advanced trend-logging. The PC can be connected to the CSC controller either directly, via a single twisted, shielded pair cable, or remotely, via phone lines with an optional modem. For more information on connecting the PC to the controller, refer to "PC Connection" in the "Field Wiring" section of this manual.

For the most convenience and best operation, the PC should be considered dedicated to the MicroTech system. However, you can exit the Monitor program to perform other tasks without affecting equipment control. Refer to the user's manual supplied with the Monitor software for additional information.

PC Specification

A direct or remote connected computer can be used for monitoring CSC and unit operation, changing setpoints, scheduling, trend logging, downloading software, and diagnostics. The PC must be an IBM or 100% true compatible. Table 10 shows the preferred and minimum PC specifications.

Network Master Panel

The MicroTech Network Master Panel (NMP) allows the CSC and its associated units to be incorporated into a building-wide network with other MicroTech unit and auxiliary controllers. In conjunction with a PC and Monitor software, it gives the building operator the capability to perform advanced equipment control and monitoring from a central or remote location. The following features are provided by the optional NMP:

- Remote unit monitoring
- Advanced scheduling features
- Advanced alarm management
- Global operator override by unit type
- Demand metering
- Historical electrical data logging

Open Protocol

MicroTech Open Protocol™ provides an interface between the CSC and the building automation system of one of many participating manufacturers. With Open Protocol, the building automation system can do the following:

- Monitor CSC schedule statuses
- Monitor most controller setpoints, parameters, and alarms
- Set most controller setpoints and parameters
- Set up multiple-unit control groups

In an Open Protocol application that includes a CSC, the MicroTech Open Protocol Master (OPM) Panel is not required because the CSC performs its functions. For further information, contact your McQuay sales representative.

Table 10. PC Specification

Preferred Configuration	Minimum Configuration
486DX processor, 66MHz or better	386SX processor, 16 MHz
8 MB of RAM or better	4 MB of RAM
120 MB hard disk drive or better	60 MB hard disk drive
3½" floppy disk drive	3½" floppy disk drive
Serial port (9 pin male)	Serial port (9 or 25 pin male)
Parallel port	—
Internal time clock, battery backed	Internal time clock, battery backed
Super VGA graphics capability	VGA graphics capability
Super VGA monitor	VGA monitor
Printer	—
Bus mouse or trackball	Serial mouse or trackball*
101 enhanced keyboard	101 enhanced keyboard
9600 baud modem, compatible with the AT command set (optional)	1200 baud modem, compatible with the AT command set (optional)
MS-DOS@ 6.2 or higher	MS-DOS@ 5.0
Microsoft@ Windows™ 3.1 or higher	Microsoft@ Windows™ 3.1
MicroTech@ Monitor™ for Windows software	MicroTech@ Monitor™ for Windows software

* If a serial pointing device is used, there must be another serial port available for connecting the PC to the MicroTech controller.

Installation

Panel Location and Mounting


The CSC is suitable for indoor use only. Table 11 lists the allowable temperature and humidity ranges. Locate the panel at a convenient height, and allow adequate clearance for the door swing. Mount the panel to the wall with screws or bolts. Four 1/4-inch openings are provided at the corners of the panel. The panel weighs approximately 60 lbs. (27 kg). Figure 13 shows the panel dimensions.

The CSC is equipped with special door hinges that have a friction adjustment screw. By adjusting this screw you can prevent the panel door from swinging open or closed unexpectedly.

Table 11. CSC Environmental Specifications

Panel State	Temperature	Relative Humidity
Operating	30 – 100°F (–1 – 38°C)	10 – 95% (noncondensing)
In storage	0 – 125°F (–18 – 52°C)	10 – 95% (noncondensing)

Figure 13. CSC Dimensions




Sensor Installation

Figures 14 and 15 show the dimensions of the water temperature sensors and thermowell used with the CSC.


All temperature sensors are negative temperature coefficient thermistors.

Figure 14. Immersion Sensor



The brass well screws into 1/2-inch NPT saddle or Thredolet® fitting furnished by the installing contractor. The brass well will withstand a maximum temperature of 250°F and a maximum static pressure of 250 psig.

Figure 15. Brass Thermowell



Field Wiring

Following are descriptions of the various field wiring requirements and options. A typical field wiring diagram is shown in Figure 16. Wiring must comply with the National Electrical Code and all local codes and ordinances. The warranty is void if wiring is not in accordance with these instructions.

The panel is separated into high and low voltage sections. The power wiring should enter the bottom knockout on the right side of the panel in the high voltage section. Wiring from the Output Board should enter through one of the $\frac{7}{8}$ -inch knockouts in the high voltage section. Communications wiring, wiring to the ICM Terminal Board, and wiring to the AOX-4 should enter through the top of the panel in the low voltage section through one of the $\frac{1}{2}$ -inch knockouts provided.

Note: High voltage wires should not pass through the low voltage section and the low voltage wires should not pass through the high voltage section.

Power

⚠ WARNING

Electric shock hazard.
Can cause personal injury or death.

This equipment must be properly grounded.

All protective deadfront panels must be reinstalled and secured when power wiring is complete.

The CSC requires a 115 Vac power supply. The supply connects to terminals L1 and L2 in the high voltage section of the panel. The panel must be properly grounded by connecting the ground lug (GRD) to earth ground. Refer to Figure 16. Power wiring must be sized to carry at least 5 amps.

To gain access to the high voltage section, remove the deadfront barrier. It is attached to the panel with five $\frac{5}{16}$ -inch hex screws. Replace this deadfront when the wiring is complete.

Network Communications

For network communications to occur, a twisted, shielded pair cable must be connected between the CSC and its associated MicroTech unit or network controllers. This interconnecting, "daisy-chain" wiring is shown in Figure 16. Network communications is accomplished using the RS-485 interface standard at 9600 baud.

About MicroTech Network Architecture

All controllers in a MicroTech network are assigned a "level"; level 1, level 2, or level 3. All networks must have one level-1 controller to coordinate communications. Multiple level-2 controllers connect to the level-1 controller with a communications "trunk," an isolated section of the daisy-chained network wiring. In Figure 16, the network wiring between all controllers is a trunk. Multiple level-3 controllers can be connected to a level-2 controller with a separate trunk. *The maximum allowable length of a communications trunk is 5000 feet.*

Cable Specification

The network communications cable must meet the following minimum requirements: twisted, shielded pair with drain wire, 300 V, 60°C, 20 AWG, polyethylene insulated, with a PVC outer jacket (Belden 8762 or equivalent). Some local codes or applications may require the use of plenum rated cable. *Do not install the cable in the same conduit with power wiring.*

Note: Ideally, one continuous piece of cable should connect any two controllers. This will reduce the risk of communications errors. If the cable must be spliced, use crimp-type butt connectors (good) or solder (best). Do not use wire nuts.

Wiring Instructions


The network connection to the CSC and unit controllers is at port B on their MCB boards. As shown in Figure 8, field wiring to port B on these controllers can be accomplished by connecting the network cable to terminals B+, B-, and GND in the CSC; terminals 84, 85, and 86, in each 200-series centrifugal chiller, terminals 137, 138, and 139 in each reciprocating chiller, and terminals 53, 54, and 55 in each screw chiller.

Note that the chiller designations shown in Figure 16 ("Chiller #1" through "Chiller #4"), are established by the network address, not the physical position of the unit in the daisy chain. The networked controllers can be wired in any order. For example, the CSC could be connected between Chiller #1 and Chiller #2. *It is highly recommended that the installing contractor keep track of the physical order of the controllers on the daisy-chained trunk.* This will facilitate troubleshooting any network communications problems that may occur. For more on the network address, see "Addressing the Controllers" in the "Network Commissioning" section of this manual.

Use the following procedure to perform the network wiring:

1. Before beginning, verify that the port B plug is disconnected from every controller on the communications trunk being wired. These plugs will be connected during the commissioning procedure. This precaution prevents stray high voltage from damaging the controllers. Any voltage more than 12 V can damage the board's communications drivers.
2. Connect the network cable in a daisy-chain manner as shown in Figure 16. Use caution to ensure that the correct polarity is maintained at each controller. Be sure to connect each cable's shield to the controllers as shown in the figure. The positive (+), negative (-), and shield (ground) conductor must be continuous over the trunk.

Figure 16. CSC Field Wiring Schematic



PC Connection

Regardless of whether a PC is connected directly or remotely via phone lines, the connection to any MicroTech controller is at port A on the MCB. It is best to connect a PC to a level-1 controller because faster data transmission will result; however, a PC can be connected to any level-2 controller that does not have level-3 controllers associated with it. Either way, the PC will have access to the entire network (see note below). In the typical application, the CSC is a level 1, and the chillers are level 2. See "Network Communications" above for more on network architecture.


It is possible to connect two or more PCs to the network, but only one PC can be connected to any one controller. The PC that is used most often should be connected to the level-1 controller for better performance. For example, you may have one PC at the building that you use during the week and another PC at home that you occasionally use on weekends. In this situation, you may want to connect the on-site PC to the level-1 controller and the modem for the off-site PC to a level-2 controller.

Note: If a PC is connected to a level-2 controller, a level-1 controller must be set up to poll that level-2 controller so that the PC will have access to the entire network. For information on how to set up the level-1 controller to poll the level-2 controller, see the operation manual for the particular controller being used.

Direct Connection

An RS-232 communications cable kit allows a PC to directly connect to any MicroTech controller. It is available from McQuay International. The cable has a female DB9 connector for connection to the PC's 9-pin serial port. (If the PC has a 25-pin serial port, obtain an adapter.) The cable length is 12 feet. If more length is required, a twisted, shielded pair cable can be spliced into the kit cable (see "Cable Specification" below). If this is done, splice the conductors with crimp-type butt connectors (better) or solder (best).

Figure 17. RS-232 Cable Pinouts for 9-pin Serial Ports (AMP Connector)



Do not use wire nuts. The maximum allowable cable length for direct connection between the PC and a controller is 50 feet. If additional length is needed, an RS-232 Cable Extension Kit (P/N 0065487001) is available from McQuay (see Bulletin No. IM 482).

Remote Connection

An analog, direct-dial telephone line is required for remote or off-site PC access to the network. The phone line should be terminated with a standard RJ-11 modular phone plug. A modem enables a remote or off-site PC to communicate with the networked controllers via phone lines.

A modem kit that can be field installed in a MicroTech controller is available from McQuay International. The kit comes complete with a 14,400 baud modem (set up for 9600 baud) and an interface cable. If a remote PC connection is required, it is recommended that the modem at the MicroTech controller be supplied by McQuay International.

Installation and wiring instructions for the modem kit are included in Bulletin No. IM 564, *MicroTech Modem Kit*. This bulletin is included with the kit.

Cable Specification for Direct PC Connection

A properly terminated, twisted, shielded pair cable is required to directly connect a PC to a MicroTech controller. The cable must meet the following minimum requirements: twisted, shielded pair with drain wire, 300 V, 60°C, 20 AWG, polyethylene insulated, with a PVC outer jacket (Belden 8762 or equivalent). It must also be properly terminated to an AMP plug on one end and a female DB9 or DB25 connector on the other. See Figures 15 and 16 for cable pinouts.

The DB9 or DB25 connector is for connection to a 9-pin or 25-pin serial port on the PC. Note that some local codes or applications may require the use of plenum rated cable. Do not install the cable in the same conduit with power wiring.

Note: A factory-assembled cable that meets the above specification is provided with the PC Communications Cable Kit. This cable has a DB9 connector.

Figure 18. RS-232 Cable Pinouts for 25-Pin Serial Ports (AMP Connector)




Table 12. Analog/Digital Inputs and Outputs

CSC Feature	AI										DI			AO			DO						
	Common ChW Supply Temp	Common ChW Return Temp	Leaving CndW Temp ①	Entering CndW Temp ①	Outdoor Air Temperature ②	Decoupler Temp	Decoupler Flow Rate	ChW Loop Differential Press	Ext ChW Reset Signal	Ext Demand Limiting Signal	External Start/Stop	ChW Reset Override	Cooling Tower Alarm	Secondary Pump 1-6 Status	Cooling Tower Bypass Valve	ChW Loop Bypass Valve or Secondary Pump VFD	Secondary Pump VFD 2	Alarm Output	Secondary Pump 1	Secondary Pump 2	Secondary Pump 3-6	Cooling Tower 1	Cooling Tower 2-12
Standard chiller sequencing control	✓																						
Decoupled chiller sequencing control	✓					✓	✓																
External Demand limiting										✓													
Unit leaving chilled water control																							
Common lvg. chilled water control	✓																						
External reset									✓			○											
Outdoor air temperature reset					✓							○											
Return ChW temperature reset		✓										○											
Constant return ChW temp. control		✓										○											
ChW loop bypass valve control								✓								✓							
Secondary pump control: VFD								✓						✓		✓	○		✓	○			
Sec. pump control: Sequenced								✓						✓				✓	✓	○			
Sec. pump control: Lead/standby														✓				✓	○				
Cooling tower staging control			○	○									○									✓	○
Cooling tower bypass valve control			○	○	○										✓								
Optimal start	✓	✓			✓																		
Nontimed schedule override											✓												
External timeclock scheduling											✓												
Remote alarm indication																	✓						

- ✓ Input or output required
○ Input or output optional

Notes:

- Cooling tower staging and cooling tower bypass valve control require either a leaving condenser water temperature sensor or an entering condenser water temperature sensor.
- The CSC can also get the outdoor air temperature via network communications from a Network Master Panel or a building automation system with Open Protocol.

Analog Inputs

When connecting any analog input device to the CSC, the field wiring connection is made at the ICM Terminal Board (see "Wiring Instructions" below). Table 12 shows several CSC features and their required analog inputs.

Note: All analog inputs have fixed locations (see Figure 16).

⚠ CAUTION

**Ground loop current hazard.
Can cause equipment damage.**

External 4-20 mA signals must be isolated from any ground other than the MicroTech controller chassis ground. If they are not, ground loop currents could occur which could damage the MicroTech controller. If the device or system providing the external signal is connected to a ground other than the MicroTech controller chassis, be sure that it is providing an isolated output, or condition the output with a signal isolator.

Chilled Water Supply Temperature Sensor

The common chilled water supply temperature sensor is used when standard chiller sequencing control, decoupled chiller sequencing control, or common leaving chilled water control is required. See Figure 1, "Typical Chilled Water System" for the location of the chilled water supply temperature sensor.

When using standard chiller sequencing control, the common chilled water supply temperature sensor is used by the CSC to determine when a system capacity increase by one stage is needed. The increase is determined when the leaving chilled water temperature is greater than the common chilled water supply temperature by more than an adjustable differential.

When using decoupled chiller sequencing control, the common chilled water supply temperature sensor is used by the CSC to determine when a system capacity increase by one stage is needed. The increase is determined when the decoupler line temperature is greater than the common chilled water supply temperature by more than an adjustable differential.

When using common leaving chiller water temperature control, the common chilled water supply temperature sensor is used by the CSC to set the Chiller Setpoint.

Chilled Water Return Temperature Sensor

The common chilled water return temperature sensor is used when return chilled water temperature reset or constant return chilled water temperature reset is required. See Figure 1, "Typical Simple Chilled Water System" for the location of the chilled water return temperature sensor.

When using return chilled water temperature reset, the System Setpoint is determined by the common chilled water return temperature.

When using the constant return chilled water temperature reset, the System Setpoint is reset by a constant return Change-and-Wait function to maintain the common chilled water return temperature.

Condenser Water Temperature Sensors

The condenser water temperature sensors are used for cooling tower staging control and cooling tower bypass valve control.

When cooling tower stage control is required, the first tower stage will be turned on when the common entering condenser water temperature exceeds the Stage 1 Setpoint (adjustable on the CSC's keypad menu 18 or using Monitor software).

When cooling tower bypass valve control (optional) is used, the CSC will maintain the common entering condenser water temperature at the Valve Setpoint or Stage Setpoint (adjustable on the CSC's keypad menu 18 or using Monitor software).

Note: Cooling tower staging control and cooling tower bypass valve control each require either a leaving condenser water temperature sensor or an entering condenser water temperature sensor.

Outdoor Air Temperature Sensor

The outdoor air temperature sensor is used to reset each chiller's leaving evaporator water temperature setpoint to equal the common chilled water supply temperature.

Decoupler Temperature Sensor

The decoupler temperature sensor is used when decoupled chiller sequencing control is required. See Figures 3a through 3d for the locations of the decoupler line temperature sensor.

The decoupled chiller sequencing control will increase the system capacity by one stage when the decoupler line temperature is greater than the common chilled water supply temperature by more than an adjustable differential.

Decoupler Flow Rate Sensor

The decoupler flow rate sensor is used by the CSC to determine when the system capacity should be decreased by one stage. See Figures 3a through 3d for the location of the decoupler flow rate sensor.

When the flow rate from supply to return in the decoupler line is greater than the flow rate of the next chiller(s) to be staged off by more than the adjustable differential, the system capacity may be reduced by one stage. Note that since flow is only measured from supply to return, a uni-directional flow meter is sufficient.

Chilled Water Loop Differential Press. Transducer

The chilled water loop differential pressure transducer is used when chilled water loop bypass valve control, secondary pump control, or secondary pump control variable speed is required. See Figure 3b, *Variable-Speed Secondary Pump*, Figure 3d, *Sequenced Secondary Pumps*, and Figure 4, *Pressure-Controlled Loop Bypass* for the locations of the chilled water loop differential pressure transducer.

When chilled water loop bypass valve control is used, the chilled water loop differential pressure transducer allows the CSC to modulate a bypass valve as required to maintain an adjustable differential pressure setpoint.

When variable speed secondary pump control is used, the chilled water loop differential pressure transducer allows the CSC to maintain a desired pressure across the chilled water loop using PI (proportional-integral) control.

When sequenced secondary pump control is used, the chilled water loop differential pressure transducer allows the CSC to maintain a constant pressure difference between the secondary and return lines.

External Demand Limiting Signal

An external I-5 Vdc, 2-10 Vdc, or 4-20 mA signal can be used to provide demand limiting for all chillers included in a CSC network.

Demand limiting prevents chillers from operating above a specified capacity (% RLA for centrifugal; stages for reciprocating and screw). As the demand limiting signal varies between I-5 Vdc, 2-10 Vdc, or 4-20 mA, the %RLA or maximum number of stages available in each chiller varies. For more on demand limiting, refer to "Demand Limiting" in the "Load Limiting Control" section of Bulletin No. OM 127, *MicroTech Chiller System Controller*.

External Chilled Water Reset Signal

The external reset option resets each chiller's leaving evaporator water temperature according to a I-5 Vdc, 2-10 Vdc, or 4-20 mA signal.

If the external reset signal is less than or equal to 4 mA (1 Vdc), the System Setpoint will equal the Minimum System Setpoint (adjustable on the CSC's keypad Menu 17 or by a PC using Monitor software). If the external reset signal equals 20 mA (5 Vdc), the System Setpoint will equal the Maximum System (adjustable on the CSC's keypad Menu 17 or by a PC using Monitor software). For more on reset, refer to "Reset" in the "Chilled Water Temperature Control" section of Bulletin No. OM 127, *MicroTech Chiller System Controller*.

Analog Inputs Cable Specifications

The cable for analog inputs must meet the following minimum requirements: twisted, shielded with drain wire, 300 V, 60°C, 20 AWG, polyethylene insulated, with a PVC outer jacket. Depending on the application, either two conductors (Belden 8762 or equivalent) or three conductors (Belden 8772 or equivalent) are required. Note that some local codes or applications may require the use of plenum rated cable. Do not install the cable in the same conduit with power wiring.

Digital Inputs

When connecting any digital input device to the CSC, the field wiring connection is made at the ICM Terminal Board (see "Wiring Instructions" below). Table 12 shows several CSC features and their required or optional digital inputs.

Note: All digital inputs have fixed locations (see Figure 16).

External Start/Stop

External start/stop is used when nontimed schedule override or external timeclock scheduling is required.

Using nontimed schedule override (manual switch) or external timeclock scheduling, the CSC will begin the Start-Up of the chillers when the external input is closed. The CSC will begin the shutdown of the chillers when the external input is open.

Chilled water reset override is an option that allows the CSC to override the any reset method that is being used.


Cooling Tower Alarm (Optional)

A double pole-double throw (DPDT) relay (minimum power usage of 30 mA) is required for each output device (e.g., fan) that could fail when the cooling tower alarm input is to be used. Note that the relay is field supplied. The DPDT relay is field wired to the CSC's output board (see "Digital Outputs" in this manual for more information about the Output Board).

When a digital output through the Output Board (Digital Output #9) is sent to the DPDT relay, the cooling tower device will be enabled. When the cooling tower device is enabled, a normally closed contact (TC1) will open. Allowing for a 30 second time delay, a normally open contact (TS1) will close, thus completing the circuit. If TS1 does not close within the 30 second time delay, an alarm will occur. These same events occur in each DPDT relay that is connected to a cooling tower digital output.

Secondary Pump #1-#6 Status - Digital Input #3-8

Figure 19. Cooling Tower Alarm Field Wiring




Analog Outputs

Note: All analog outputs have fixed locations (see Figure 16).

⚠ CAUTION

Analog output signals (voltage mode) must be isolated from any ground other than the MicroTech controller chassis ground. If they are not, ground loop currents could occur which could damage the MicroTech controller.




The CSC controls a bypass valve to maintain the either the entering or leaving condenser water temperature at the Valve Setpoint or the Stage Setpoint when condenser flow is confirmed.

The CSC uses a secondary chilled water pump with variable frequency drive (VFD) to maintain a desired pressure differential across the chilled water loop.

The CSC can operate two variable speed secondary pumps in either a lead/standby or sequenced control configuration. The output signal at A02 is always the same as AO1.

Figure 21. Analog Outputs Field Wiring Connections



Digital Outputs

The CSC provides digital output signals from the MCB's Digital Output connector to the Output Board (OB) via a ribbon cable. When the MCB commands a certain output, the designated relay on the OB energizes and drives an AC or DC load. Note that power to loads must be field supplied and the proper relay (AC, DC, or dry contact) must be selected. For more information on the OB, refer to "Output Board" in the "Component Data" section of this manual, or see Bulletin No. IM 606, *MicroTech Solid-State Relay Kit*.

Note: All digital outputs have fixed locations (see Figure 16).

Alarm LED and Alarm Horn

Both the Alarm LED and Alarm Horn are internally wired to DO 0 and DO 1. They are not intended for field wiring; however, they can be wired to by installing a relay in the socket.

Alarm Output

The alarm output is used for remote alarm indication (location of an alarm output in a separate location than the CSC).

Secondary Pump 1

The secondary pump 1 digital output is used to start and stop the secondary pump #1. When the proper digital output signal is sent by the CSC through the secondary pump 1 digital output, the secondary pump #1 will start.

Secondary Pump 2-6

The secondary pump 2-6 digital outputs are used (if needed) to start and stop the secondary pumps #2-#6. When the proper digital output is sent by the CSC through the secondary pump 2-6 digital outputs, secondary pumps #2-#6 will start.

Cooling Tower 1

The cooling tower 1 digital output is used to start and stop the cooling tower fan #1 or other device. When the proper digital output is sent by the CSC through the cooling tower 1 digital output, cooling tower fan #1 or other device will start. The CSC will control the tower fan #1 or other device by using the cooling tower staging control feature.

Cooling Tower 2-12

The cooling tower 2-12 digital outputs are used to start and stop the cooling tower fans #2 through #12. When the proper digital output is sent by the CSC through the cooling tower 2-12 outputs, cooling tower fans #2 through #12 will start, depending on what number stage is chosen. The CSC will control the tower stages by using the cooling tower staging control feature.

Network Commissioning

The purpose of network commissioning is to establish and verify communications between the CSC and its associated centrifugal, reciprocating, or screw chillers. (It is not to establish and verify HVAC equipment *operation*.) Network commissioning can be done independently of the unit commissioning procedures; however, *if it is done before the units are commissioned, care should be taken to assure that the chillers do not start*. To do this, see the "CSC and Chiller Controller Initial Setup" section of Bulletin No. OM 127, *MicroTech Chiller System Controller*.

To commission the network, you must be familiar with the operation of the keypad/display. For information, see the "Getting Started" portion of Bulletin No. OM 127.

Before any unit is allowed to operate, it must be commissioned in accordance with the instructions in the MicroTech unit controller installation literature and the model specific unit installation literature (see Tables 1 and 3). In addition, the CSC and its associated unit controllers must be set up so that they work properly together. This setup, which can be done before or after the network is commissioned, is described in Bulletin No. OM 127.

A PC is not required to commission networks that include only CSC(s) and associated chillers because communications can be verified by using the CSC's keypad/display. However, if you want to use a PC to verify network communications, you can. The PC must be equipped with MicroTech **Monitor™** software.

Note: The term "HVAC equipment" refers to the different McQuay® and AAF® brand products monitored and controlled in a MicroTech network.

Addressing the Controllers

For network communications to occur, each controller in the network must have a unique network address. A controller's hex switch setting defines its network address. The hex switch setting is determined by the project engineer or the

customer. The engineer or customer should prepare a schedule indicating what the hex switch settings on each controller should be. The schedule should then be given to the commissioning technician or engineer so they can set up the software. For more on hex switch settings, see "Microprocessor Control Board" in the "Component Data" section of this manual.

After changing a hex switch setting, power to the MCB must be cycled to set the new address into memory. In the CSC, this can be done by pressing the ON/OFF switch (CB1) to the "OFF" position and back to the "ON" position. In the unit controllers, this can be done in a variety of ways. Refer to the individual installation manuals for more information on cycling power to the MCBs.

A level-1 controller will have a hex switch setting of 00. The level-2 controllers will have hex switch settings between 01 and 40 (64 decimal). There must be no gaps in the level-2 hex switch sequence and no duplicate settings.

The Typical Network

The typical network includes one CSC and one to eight centrifugal, reciprocating, or screw chillers, or a combination of up to eight centrifugal, reciprocating, or screw chillers. It may also include other level-2 unit or auxiliary controllers that could be accessed with a PC via network communications. In this case, the CSC is the level-1 controller and the unit controllers are level-2 controllers. Since the CSC is level 1, its hex switch setting must be 00. The hex switch settings of the level-2 controllers must start at 01 and continue consecutively to a maximum of 40 (decimal 64). There must be no gaps in the sequence and no duplicate settings. As long as these rules are followed, a level-2 controller's hex switches can be set to any value. To keep the system simple, you should consider addressing the chillers according to their designations.

For example, assume that a MicroTech network includes a CSC, two centrifugal chillers, two screw chillers, and one rooftop unit. One possible addressing scheme is as follows:

Hex Switch Setting	Controller
00	c s c
01	Chiller #1 (centrifugal)
02	Chiller #2 (centrifugal)
03	Chiller #3 (screw)
04	Chiller #4 (screw)
05	Rooftop air handling unit

Note: If a PC or modem is connected to a level-2 controller, that controller should have as low an address as possible. This will improve the performance of network communications because it will reduce the required value of the CSC's Total Slaves parameter and thus the amount of polling. For example, if a modem is connected to Chiller #3, you should consider setting Chiller #3's hex switches to "01." See the "CSC and Chiller Controller Initial Setup" section in Bulletin No. OM 127 for more information.

Networks With an NMP

If a CSC is included in a network that has an NMP, the NMP must be the level-1 controller. In this case, a CSC is a level-2 controller and the unit controllers are also level-2 controllers. Since the NMP is level 1, its hex switch setting must be 00. The hex switch settings of the level-2 controllers must start at 01 and continue consecutively to a maximum of 40 (decimal 64). There must be no gaps in the sequence and no duplicate settings. As long as these rules are followed, a level-2 controller's hex switches can be set to any value. Two or more CSCs and multiple units are possible in this type of network.

For example, assume that a MicroTech network includes an NMP, a CSC, two centrifugal chillers, one screw chiller, and one rooftop unit. One possible addressing scheme is as follows:

Hex Switch Setting	Controller
00	NMP
01	c s c
02	Chiller #1 (centrifugal)
03	Chiller #2 (centrifugal)
04	Chiller #3 (screw)
05	Rooftop air handling unit

Networks With Two or More CSCs and No NMP

If two or more CSCs are included in a network that does not include an NMP, one of the CSCs must be the level-1 controller. In this case, the other CSCs are level-2 controllers and the unit controllers are also level-2 controllers. The level-1 CSC's hex switch setting must be 00. The hex switch settings of the level-2 controllers must start at 01 and continue consecutively to a maximum of 40 (64 decimal). There must be no gaps in the sequence and no duplicate settings. As long as these rules are followed, a level-2 controller's hex switches can be set to any value.

For example, assume that a MicroTech network includes two CSCs and ten centrifugal chillers. Each CSC will control and monitor a separate system of five chillers. One possible addressing scheme is as follows:

Hex Switch Setting	Controller
00	csc "A"
01	csc "B"
02	Chiller #1 for CSC "A"
03	Chiller #2 for CSC "A"
04	Chiller #3 for CSC "A"
05	Chiller #4 for CSC "A"
06	Chiller #5 for CSC "A"
07	Chiller #1 for CSC "B"
08	Chiller #2 for CSC "B"
09	Chiller #3 for CSC "B"
0A	Chiller #4 for CSC "B"
0B	Chiller #5 for CSC "B"

Note: The only advantage to creating a network like this is to allow a PC access to all networked controllers. If there is no PC, each CSC should be set up as a level-1 controller in a separate network as described above in "The Typical Network."

Note: If a PC or modem is connected to a level-2 controller, that controller should have as low an address as possible. A level-2 CSC should also have as low an address as possible. This will improve the performance of network communications because it will reduce the required value of the level-1 CSC's Total Slaves parameter and thus the amount of polling. For example, if a modem is connected to Chiller #2 for CSC "B" in the above example, you should consider setting the hex switches for CSC "B" to "01" and the hex switches for its Chiller #2 to "02." See the "CSC and Chiller Controller Initial Setup" section in Bulletin No. OM 127.

Minimum Controller Setup

The CSC and the centrifugal, reciprocating, or screw chiller unit controller, require a minimum of setup before the network can be commissioned. For complete information on how to do this, see the "CSC and Chiller Controller Initial Setup" section in Bulletin No. OM 127.

Connecting the Communications Trunk

Use the following three procedures to connect the and chiller controllers to the network.

Communications Cable Check

The network communications cable should have been installed in accordance with the instructions in the "Field Wiring" section of this manual. This procedure will verify that there are no shorts or stray voltages anywhere in the communications trunk.

Before beginning, verify that the port B connectors are disconnected from every controller on the trunk.

1. Verify that there is no voltage between any conductor and ground.

Use a voltmeter to test for voltage at the field wiring terminal block or directly on the port B connector of the level-I controller. With one lead on the control panel chassis (ground), check for voltage at the "+," "-", and "ground" terminals. There should be no AC or DC voltage (see the Signal and Terminal columns of Table 13). If the conductors are properly terminated, this check will test for stray voltage throughout the trunk.

Note: If you get a 2 or 3 Vdc reading, it indicates that one or more powered controllers are connected to the trunk. These controllers should be located and disconnected.

2. Verify that there are no shorts between any two conductors.

Use an ohmmeter to test for shorts at field wiring terminal block or directly on the port B connector of the level-I controller. For the three combinations of conductor pairs, there should be infinite resistance between the conductors. If the conductors are properly terminated, this check will test for shorts throughout the trunk.

Note: If you find a resistance that is high but less than infinite, it indicates that one or more non-powered controllers are connected to the trunk. These controllers should be located and disconnected.

3. Verify that the communications wiring is continuous over the trunk and that the field terminations are correct. (This step is optional but recommended; to do it, you must know the physical layout of the network's communications trunk.)

Go to the last controller on one end of the daisy-chain and place a jumper across the "+" and "-" terminals. Then go to the last controller on the other end of the daisy-chain and use an ohmmeter to test for continuity across the "+" and "-" terminals.

Remove the jumper and repeat this step for the other two conductor pairs: "+" to "ground" and "-" to "ground."

If there is continuity for each conductor pair, the wiring is continuous and it is likely (but not guaranteed) that the terminations are correct throughout the trunk.

If there is no continuity for one or more conductor pairs, there may be a break in the trunk or the terminations at one or more controllers may have been mixed up.


Table 13. Port B Voltages: AMP Type Connector

Port B (RS-485)		Acceptable Voltage Reading
Signal	Terminal	
+	4	3.0 ± 0.3 Vdc
-	3	2.0 ± 0.3 Vdc
Ground	5	0.0 ± 0.2 Vdc

Table 14. Network Communications Field Wiring Terminals

Controller	Network Comm. Field Terminal		
	+	-	Ground
CSC	T11-B+	T11-B-	T11-GND
200-Series Centrifugal Chiller	TB1-86	TB1-84	TB1-85
Reciprocating Chiller	TB7-138	TB7-137	TB7-139
Screw Chiller	TB4-54	TB4-53	TB4-55

Figure 22. AMP Connector Terminal Configuration



Level-I Controller Connection

In order for the chillers and other level-2 controllers in a network to connect and communicate with the CSC, the CSC is connected first.

1. Set the network address to 00 (level 1). See "Addressing the Controllers" above for more information.
2. Push the circuit breaker (CB1) button to power up the CSC and verify that there is power to the MCB by observing the LEDs.
3. Check the voltages of port B on field wiring terminals (T11).

Use a DC voltmeter to test for proper voltages. With the ground lead on the control panel chassis (ground), check the voltage at the "+," "-", and "ground" terminals. Refer to Table 13 for the correct voltage levels.

If no voltage or improper voltage levels are found, verify that the panel is energized.

4. Plug the network communications AMP connector into port B.

Level-2 Controller Connection

This procedure will verify that proper communications have begun for each controller as it is connected to the network. You can connect the level-2 controllers in any order; however, it is better to follow the daisy-chain as you proceed. This will make troubleshooting easier if communications problems occur.

As a result of the previous procedures, the network communications connector should be disconnected from the B port at every controller on the trunk except for the CSC. Be sure that this is true before beginning this procedure.

For communications to occur, each networked controller must have the proper hex switch setting and the proper voltages at its port B terminals.

1. Set the network address (hex switch setting) to match the address on the engineering schedule. Each controller must have a unique address.
2. Turn on power to the level-2 controller. Refer to the controller installation manuals for information on how to turn on power to each controller.
3. Check the voltages of port B directly on the AMP connector. The trunk must not be connected to the controller when you do this.

Use a DC voltmeter to test for proper voltages. With the ground lead on the control panel chassis (ground), check the voltage at the "+," "-", and "ground" terminals. Refer to Table 13 for the correct voltage levels.

If no voltage or improper voltage levels are found, verify that the controller is energized.

4. Check for proper communication trunk voltages at the field wiring terminals (if any) or directly on the connector. The trunk must not be connected to the controller when you do this.

If no voltage or improper voltages are found, check the wiring between the port terminals and the field terminals (if any). Using Table 13 and Figure 22, verify that the three conductors are properly terminated in the network communications connector. If there is still a problem, verify that the level-I controller is energized and that the communications trunk wiring is intact.

5. Plug the network connector into port B.
6. Verify communications have begun between CSC and the level-2 controller:

To verify the level-2 controllers are communicating with the CSC, use the CSC's keypad/display or a PC equipped with *Monitor™ for Windows™* software.

To verify communications using the CSC's keypad/display, go to menu 3, "Chiller Status." Select the chiller number that is being connected to the CSC. If communications exists, the screen will fill in with information about the chiller. If you get a "Comm Loss" message, communications between the CSC and chiller has not been accomplished. For more information on the keypad/display, refer to "Getting Started" in Bulletin No. OM 127.

To verify communications using *Monitor for Windows* software, network diagnostics must be performed. To run network diagnostics, select the pull-down menu "Comm." Select "Network Diagnostic," which will then display the "Network Diagnostics Parameters Setup" dialog box. Using the "Network Diagnostics Parameters Setup" dialog box, you can choose to continually loop the diagnostics, or have a single sweep of each controller being connected to the network. You can also perform the following functions:

- Display Program ID and status
- Restrict display of level-3s to units with errors
- Clear communications errors if found
- Log errors to file

As the different controllers are connected to the network, their information is displayed on the Network Diagnostic Error Display screen. By looking at the headings labeled "Address" and "Error Codes," network communications to a particular controller can be verified. If there are no error codes, network communications to the controller was successful. If the "Error Code" reads "Does not respond," a communications problem has occurred. For more on network diagnostics, see "Chapter 5 - Comm Menu" in *MicroTech Monitor for Windows* user's manual.

If a communications problem occurred, check the following items:

- Make sure the hex switches on each controller are set to the correct values.
- Make sure the controller has power supplied to it.
- Make sure the communication line is properly connected to port B.
- Make sure the controller is level 2 by directly connecting the PC to it. (You must know how to change communications passwords to do this.)

7. Go to the next controller and repeat steps 1 through 6. Do this for each controller being connected to the network.

Note: To verify communications more quickly and easily, use two people in the commissioning of the network. Because some jobs have units located throughout a building, having one person perform the commissioning procedure may be difficult. When there are two people, one person can stay at the PC connected to the level-I controller and the other person can go to each individual unit controller. Using a radio or other two-way communication equipment, they can indicate when a specific controller is connected and whether communications between the controllers is occurring.

Service Information

Wiring Diagram


The following wiring diagram is identical to the one in the CSC. It is reproduced here for your convenience. The wiring diagram in the CSC will have the locations of analog inputs and outputs and digital inputs and outputs. It is reproduced here for your convenience. The legend is shown in Figure 23.

Figure 23. CSC Schematic Legend

Component Designation	Description
CB1.....	Circuit Breaker
MCB.....	Microprocessor Control Board
ICM.....	Input Conditioning Module
OB.....	Output Board
AOX BRD.....	Auxiliary Output Expansion Board
KDI.....	Keypad Display Interface
T1.....	Transformer: 115/24 Vac
T2.....	Transformer: 24 Vac/18 Vac-CT

— 900 —	Factory Wire Number
— () —	Field Wiring Terminal
---	Field Wiring
□	Printed Circuit Board Terminal
— () —	Twisted, Shielded Pair Cable

Figure 24. CSC Schematic




Test Procedures

A listing of MicroTech related part numbers is included in the "Parts List" section of this manual. If the MCB must be replaced, refer to the "MCB Replacement" section of this manual.

Status LED Diagnostics

The MCB status LED indications can aid in controller diagnostics. If the status LEDs do not operate normally as described in the "Component Data" section of this manual (see Table 1), there is a problem with the MCB. Following are troubleshooting procedures for the various symptoms.

Figure 24. CSC Schematic (cont'd)



Red LED Remains On

If the red LED remains on after the 5-second self-test period, it is likely that the MCB is defective. However, this can also occur in some instances if there is a power supply problem. Refer to "Troubleshooting Power Problems" below.

Red and Green LEDs Off

If the red and green LEDs do not turn on after power is applied to the controller, there is likely a defective component or a problem in the controller's power distribution circuits. Refer to "Troubleshooting Power Problems" below.

Troubleshooting Power Problems

The MCB receives 18 Vac, center-tapped power from transformer T2. It then distributes both 5 Vdc and 13 Vdc power to various MicroTech components. A problem that exists in any of these components can affect the MCB and thus the entire control system. Power problems can be caused by an external short, which can blow a fuse, or a defective component, which can either blow a fuse or create an excessive load on the power supply. An excessive load can lower the power supply voltages to unacceptable levels. Use the following procedure to isolate the problem. Note that this procedure may require two or three spare MCB fuses (see parts list). Refer to the panel wiring diagram or Figure 24 as you proceed.

1. Verify that circuit breaker CB1 is closed.
2. Remove the MCB Power In connector and check for 9 Vac between the terminals on the plug corresponding to terminals 2 and 3 on the board (see Figures 2 and 15). Then check for 9 Vac between the terminals on the plug corresponding to terminals 1 and 3 on the board. (Readings of 9–12 Vac are acceptable.)
If 9 Vac is present between both sets of terminals, go to step 3.
If 9 Vac is not present between both sets of terminals, check transformers T2 and T1 and all wiring between the 115 Vac source and the Power In plug.
3. Remove power from the controller by opening circuit breaker CB1. Check the MCB power supply input fuses (F1 and F2) with an ohmmeter. See Figure 25. A good fuse will have negligible resistance through it (less than 2 ohms).
If either or both fuses are blown, replace them. Go to step 4.
If the fuses are intact, the MCB is defective.
4. Reconnect the Power In connector and disconnect all other connectors on the MCB. Cycle power to the controller (close and then open CB1) and check the power fuses.
If both fuses are intact, go to step 5.
If either fuse blows, the MCB is defective.
5. Reconnect the keypad/display ribbon cable (if equipped with keypad/display door). Cycle power to the controller and check the power fuses.
If both fuses are intact, go to step 6.
If either fuse blows, check the keypad/display and the connecting ribbon cable for shorts. Either one may be defective.
6. Reconnect the analog input ribbon cable. Cycle power to the controller and check the power fuses.
If both fuses are intact, go to step 7.

If either fuse blows, check the ICM Terminal Board, the ICMs (if any), the connecting ribbon cable, and the field wiring for shorts. Any of these may be defective. Try repeating this step after removing or swapping ICMs.

7. Reconnect the digital input ribbon cable. Cycle power to the controller and check the power fuses.

If both fuses are intact, go to step 8.

If either fuse blows, check the ICM Terminal Board, the ICMs (if any), the connecting ribbon cable, and the field wiring for shorts. Any of these may be defective. Try repeating this step after removing or swapping ICMs

8. Reconnect the digital output ribbon cable to the MCB. Cycle power to the controller and check the power fuses.

If both fuses are intact, go to step 9.

If either fuse blows, check Output Board and the connecting ribbon cable. Either of these may be defective.

9. If there are any AOX-4 boards, reconnect the expansion bus ribbon cable to the MCB; otherwise, go to step 10. Cycle power to the controller and check the power fuses.

If both fuses are intact, go to step 10.

If either fuse blows, check the analog output expansion modules (if any), the connecting ribbon cables, and the field wiring for shorts. Any of these may be defective.

10. With circuit breaker CB1 open, measure the resistance between field terminals "DC-GRD" and "5 Vdc." It should be greater than 20 ohms.

If the resistance is greater than 20 ohms, go to step 11 if the controller is equipped with at least one AOX-4 board or a modem. Otherwise, the problem is indeterminate. Obtain factory service.

If the resistance is less than 20 ohms, it is likely that the keypad/display, the Output Board, the ICM Terminal Board, or an external (field supplied) load is excessively loading the MCB's 5 Vdc power supply. Isolate the problem by taking resistance measurements on each of these devices with the wiring disconnected. The resistance across the power input terminals on the keypad/display (G and 5V) should be close to infinite. The resistance across the power input terminals on the Output Board (+ and -) should not be less than 3000 ohms. When the field wiring and the OB are disconnected, the resistance across the power input terminals on the ICM Terminal Board (H7-1 and H7-2) should be infinite. If the component resistances are proper, check the resistance of the field supplied loads (if any) and check the wiring and connections throughout the 5 Vdc power supply circuit.

11. Disconnect the connector plugs from the modem and the power plug from all AOX-4 boards (as applicable). With circuit breaker CB1 open, measure the resistance between field terminals "DC-GRD" and "13 Vdc." It should be infinite.

If the resistance is infinite, go to step 12.

If the resistance is not infinite, a short exists somewhere in the 13 Vdc power supply wiring.

12. Reconnect the Aux/Out connector plug to the MCB. If there's a modem, reconnect its AMP plug to port A. With circuit breaker CB1 open, measure the resistance between field terminals "DC-GRD" and "13 Vdc." It should steadily rise to a value greater than 5000 ohms (within approximately 30 seconds).

If the resistance rises above 5000 ohms, go to step 13.


If the resistance does not rise above 5000 ohms, the MCB is defective.

13. One at a time, reconnect the modem and each AOX-4 board (as applicable). Each time a component is reconnected, measure the resistance between field terminals "DC-GRD" and "13 Vdc." It should steadily rise to a value greater than 5000 ohms.

If the resistance rises above 5000 ohms, repeat this step until the modem and all AOX-4 boards (as applicable) have been checked out. If the problem persists, it is indeterminate. Obtain factory service.

If the resistance does not rise above 5000 ohms, the modem or the AOX-4 board just connected is defective. (With the power plug disconnected, the resistance across an AOX-4 boards "DC" and "G" terminals should not be less than 3 million ohms.)

Figure 25. MCB Power Supply Terminals



Troubleshooting Communications Problems

If a communications problem occurs, check the following items:

- Check the port B voltages
- Check the port B fuses
- Check the network integrity
- Check the network addressing

The best way to accomplish these checks is to perform the start-up procedures in the "Network Commissioning" section of this manual. If these procedures have performed and the problem persists, obtain factory service.

Troubleshooting the Keypad/Display Interface

The Keypad/Display Interface is connected to the MCB via a ribbon cable and discrete wiring for the back light. The MCB provides operating voltages, control signal outputs for the display, and input conditioning for the keypad inputs.

Display is Hard to Read

The clarity of the LCD display can be affected by ambient temperature. Typically, less contrast will result with cooler temperatures. If the display is difficult to read, adjust the contrast trim pot, which is located on the back of the keypad/display assembly.

Back Light Not Lit

The Keypad/Display Interfaces supplied with the CSC are equipped with a back light. If the light does not come on, check for 5 Vdc at terminal 9 on the IDC connector on the KDI and for 5 Vdc on the CSC field wiring terminal strip.

Check for 5 Vdc on the IDC connector on the To check for the 5 Vdc on the IDC connector, pull back the plug about one-eighth of an inch and place the test leads against the exposed pins. If there is no voltage, check the wiring and the connections between the CSC's 5 Vdc field wiring terminal strip and the KDI. If the wiring is intact the MCB is probably defective.

Display is Blank or Garbled

If the MCB appears to be functioning properly and the display is completely blank or garbled, perform the following procedure:

1. Try cycling power to the controller by opening and then closing circuit breaker CB1 (see note below).
2. Try adjusting the contrast trim pot, which is located on the back of the keypad/display assembly. If the contrast trim pot has no effect, it is likely that either the keypad/display or its ribbon cable is defective.
3. After removing power from the controller, check the ribbon cable and connections between the keypad/display and the MCB. Look for bent pins. Restore power after reconnecting the ribbon cable.
4. Try swapping a known good ribbon cable and keypad/display. Swap these components separately to isolate the problem. Remove power from the controller before disconnecting the suspect component, and restore power after connecting the replacement component. If the problem persists, it is likely that the MCB is defective.

Troubleshooting Analog Inputs

An analog input, such as a room temperature sensor, is connected to the Analog Input terminal strip on the Input Conditioning Module Terminal Board. The analog input is then conditioned by the Input Conditioning Module (ICM). The conditioned input is transferred to the MCB via a ribbon cable.

Analog Input not Read by the MCB

If the MCB appears to be functioning properly and the analog input is not being read by the MCB, perform the following procedure:

1. Try cycling power to the controller by opening and then closing circuit breaker CB1.
2. Check the ribbon cable, power wiring connector (H7), and the field wiring connections from the analog input device. Look for bent pins, cable on backwards, or miswires. Restore power after reconnecting all cables and wires.
3. If the problem persists, try swapping a known good ribbon cable, an Input Conditioning Module (ICM), or analog input device. Swap these components separately to isolate the problem. Remove power from the controller before disconnecting the suspect component, and restore power after connecting the replacement component. If the problem persists, it is likely that the MCB is defective.

Troubleshooting Digital Inputs

A digital input device is connected to the Digital Input terminal strip on the Input Conditioning Module Terminal Board. 24 Vac, supplied by the CSC, is sent to the digital input device via a supply wire. When a contact in the digital device makes, a return signal is sent back to the Digital Input terminal strip. The signal is then conditioned by the Input Conditioning Module (ICM). The conditioned digital input is then sent to the MCB via a ribbon cable.

Digital Input not Read by the MCB

If the MCB appears to be functioning properly and the digital input is not being read by the MCB, perform the following procedure:

1. Try cycling power to the controller by opening and then closing circuit breaker CB1.
2. Check the ribbon cable, power wiring connector (H7), and the field wiring connections from the digital input device. Look for bent pins, cable on backwards, or miswires. Restore power after reconnecting all cables and wires.
3. If the problem persists, try swapping a known good ribbon cable, an Input Conditioning Module (ICM), or a digital input device. Swap these components separately to isolate the problem. Remove power from the controller before disconnecting the suspect component, and restore power after connecting the replacement component. If the problem persists, it is likely that the MCB is defective.

Troubleshooting Analog Outputs

Variable voltage or current control signals are sent to analog outputs by the MCB through the Analog Output Expansion Module (AOX-4). The MCB sends a voltage or current signal to the AOX-4 via a ribbon cable. Jumpers on the AOX-4 determine what type of output will be sent to the analog output device. The analog output signals are sent from the AOX-4 by connecting a two-pin Phoenix connector to the Analog Output Ports on the AOX-4. The analog output device also has an external power supply, usually 24 Vac, that is not powered by the CSC.

Analog Output Device is not Operating Correctly

If the MCB appears to be functioning properly and the analog output device is not operating correctly, perform the following procedure:

1. Try cycling power to the controller by opening and then closing circuit breaker CB1.
2. Check the ribbon cable(s), power wiring from CSC to the AOX-4, field wiring connections from the AOX-4 to the analog output device, and the power wiring from the external power supply to the output device. Look for bent pins, cable on backwards, or miswires. Restore power after reconnecting all cables and wires.

Note: If the analog output signal supplied by the CSC is a voltage signal (0-5, 0-10 Vdc), the external power supply ground must be grounded to the Micro-Tech Controller's chassis ground.
3. If the problem persists, try swapping a known good AOX-4, ribbon cable(s), analog output device, or external power supply. Swap these components separately to isolate the problem. Remove power from the controller and analog output device before disconnecting the suspect component, and restore power after connecting the replacement component. If the problem persists, it is likely that the MCB is defective.

Troubleshooting Output Boards


Each output on the Output Board consists of a solid-state relay, an LED, 5-amp fuse, and an MOV (metal oxide varistor).

Normally, when the MCB commands an output to energize, the solid-state relay contacts will close and the LED will glow. The contacts of each solid-state relay are in series with a 5-amp fuse. These fuses resemble small resistors and are located on the board adjacent to the relays they serve (see Figure 26). The fuses are pressed into place. They can be removed with a needle nose pliers. The MOV, which is located on the underside of the output board, protects the solid-state relay from high transient voltages. MOVs are part of the output board and cannot be replaced.

Following are troubleshooting procedures for various symptoms of output board problems

Note: It should be possible to determine whether a solid-state relay is defective by using these procedures. However, if you need more information on troubleshooting them, refer to "Troubleshooting Solid-State relays" below.

Figure 26. Output Board Relay Socket



⚠ WARNING

Electric shock hazard.

Can cause severe injury or death.

Even when power to the panel is off, solid-state relay socket terminals 1 and 2 on the output board could be connected to high voltage (see Figure 26). Avoid them.

One LED Out

If one of the Output Board LEDs fails to illuminate when the MCB is commanding the associated output to energize, perform the following procedure:

1. Remove power from the controller by opening CB1. Swap the suspect relay with a known good relay. Try to choose a relay that will not affect unit operation. Restore power by closing CB1.
If the LED does not light, go to step 2.
If the LED lights, the suspect relay is defective.

2. Remove power from the controller. Check the ribbon cable and connections between the OB and the MCB. Look for bent pins.
If the cable and connections are intact, go to step 3.
3. Remove the relay from the suspect socket. Install a 330-680 ohm resistor between terminals 3 and 5 as shown in Figure 26. Restore power by placing CB1 to the ON position. The LED should light regardless of the controller's command.
If the output LED illuminates, it is likely that the MCB is defective.
If the output LED does not illuminate, the output board is defective.

All LEDs Out

If the MCB is commanding at least two outputs to energize and none of the Output Board LEDs are lit, perform the following procedure:

1. Verify that 5 Vdc is present at the Output Board's power terminals.
If 5 Vdc is not present, go to step 2.
If 5 Vdc is present, check the ribbon cable and connections between the output board and MCB. Look for bent pins. If the cable and connections are intact, the Output Board or the MCB is defective.
2. Remove power from the controller by placing CB1 to the OFF position. Disconnect at least one wire from the power input terminals of the Output Board. The resistance should not be less than 3000 ohms.
If the resistance is greater than the acceptable value, go to step 3.
If the resistance is less than the acceptable value, the Output Board is defective.
3. Check the discrete wiring and connections between the following: Input Conditioning Module Terminal Board (T10) and OB input power field wiring terminals, CSC field wiring terminal strip and Input Conditioning Module Terminal Board (H7), Aux/Out terminal strip and the CSC field wiring terminal strip.
Note: The MCB Aux/Out connector plug terminals displace wire insulation to make contact with the conductor. If a faulty Aux/Out connections is suspected, try pressing down on the wire in the terminals with a small screwdriver.

LED Lit, Output not Energized

If the LED of a suspect output is lit but the load connected to it is not energized, and everything is intact between the MCB and the coil side of the relay, perform the following procedure to isolate the problem:

1. Verify that 24 or 120 Vac power is present at the suspect output's screw terminal on the Output Board.
2. Remove power from the controller by opening CB1. Pull the 5-amp fuse on the contact side of the relay and check it for continuity with an ohmmeter.
If the fuse is not bad, reinstall it and go to step 3.
If the fuse is bad, replace it and inspect the load and associated wiring before restoring power. Note that a fuse from an unused output can be substituted for the bad fuse.
3. Remove power from the controller by opening CB1. Swap the suspect relay with a known good relay. Try to choose a relay that will not affect unit operation. Restore power by closing CB1.
If the output load energizes, the suspect relay is bad. Replace the relay.
If the output load does not energize (when LED is lit again), check the load circuit wiring and components.

Output Energized, LED not Lit

If the LED of a suspect output is not lit, but the load connected to it is energized, either the solid-state relay or the MOV is bad. The solid-state relay contacts and the MOV, which are in parallel, can both fail closed. Perform the following procedure to isolate the problem:

1. Remove power from the controller by opening CB1. Pull the solid-state relay from the suspect output's socket.

2. Restore power by closing CB1.

If the output load remains energized when there is no relay in the socket, the output's MOV has failed and thus the Output Board must be replaced.

If the output load de-energizes, the relay that was pulled is defective.

Contact Chatter

Contact chatter is very rapid opening and closing of contacts. It is usually caused by low voltage at the electromechanical relay or contactor coil. If contact chatter is occurring on a relay or contactor connected to one of the Output Board solid-state relays, it is also possible that a faulty connection exists on the power supply terminals of the Aux/Out plug connector on the MCB, on the CSC field wiring terminals, on connector H7 of the Input Conditioning Module Terminal Board, or the wiring between the Input Conditioning Module Terminal Board (T10) and the Output Board. In very rare instances, contact chatter can be caused by a faulty solid-state relay. Perform the following procedure to isolate the problem.

1. Verify that the voltage at the load's power supply and at the solid-state relay contacts is adequate.
2. Remove power from the controller by opening CB1. Swap the suspect relay with a known good relay. Try to choose a relay that will not affect unit operation. Restore power by closing CB1.

If the chatter does not stop, go to step 3.

If the chatter stops, the suspect relay is defective. Replace the relay.

3. Remove power from the controller by opening CB1. Try to improve the connections in the Aux/Out plug insulation displacement terminals by pressing down on the wires with a small screwdriver.
4. Check all other wiring and connectors for bent pins or miswires.

If the chatter does not stop, the electromechanical relay or contactor is probably defective.

Troubleshooting Solid-State Relays

As shown on the unit wiring diagrams, the solid-state relays on the Output Boards all have normally open "contacts." Actually, these contacts do not exist as they do in an electromechanical relay. Instead of using contacts to switch the load, the solid-state relay changes its resistance from low (closed), when it is energized, to high (open), when it is de-energized. (This high resistance is approximately 100K ohms.) Because the output circuit through the solid-state relay remains continuous regardless of whether the relay is energized, troubleshooting a solid-state relay with a voltmeter can be tricky.

In a typical circuit, a power source is connected across a single relay output and a load (see Figure 27). In this circuit, a solid-state relay will behave like an electromechanical relay. If the relay is energized, the relay output will be hot. If the relay is de-energized, voltage cannot be measured at the relay output.

The circuit shown in Figure 28 is similar to a typical circuit; the difference is that there is an open set of contacts, or a disconnection between the relay output and the load. In this circuit, a solid-state relay will not behave like an electromechanical relay. If the solid-state relay is energized, the relay output will be hot (as expected). However, if the solid-state relay is de-energized, the relay output will still appear to be hot. This is because the relay output and the voltmeter form a continuous circuit in which the relay's resistance, though high, is insignificant compared to the voltmeter's resistance.

This means that nearly all the voltage is dropped across the voltmeter. Therefore, the voltmeter indicates that voltage is present. If a low wattage light bulb of the appropriate voltage is used instead of a voltmeter, the bulb's low resistance will load the circuit enough to eliminate the false voltage indication. In this situation, an incandescent test lamp is a better tool than a voltmeter.

Figure 27. Testing a Typical Relay Circuit





Figure 28. Testing a Relay Circuit with a Disconnection



MCB Replacement

If an MCB board is defective and must be replaced, the proper controller software must be loaded into the replacement MCB. This can be done either at the factory or at the building site-if a PC equipped with appropriate Monitor software is available.

The factory will download the proper controller software into a replacement MCB board before it is shipped if you include the CSC's program code with the replacement MCB part order. If the program code is not provided, the MCB board will be shipped without software.

Job-specific Monitor software includes each unit, and auxiliary controller's program. Therefore, it is possible to download the proper controller software to a replacement MCB at the building site if a PC equipped with that job's Monitor software is available. In addition, if the controller's configuration data was stored on the PC hard drive prior to the MCB failure, the exact configuration data (including all keypad programmable setpoints and parameters) can be restored. Refer to the user's manual supplied with the Monitor software for more information.

Parts List

Component Designation	Description	Part No.
MCB	① Microprocessor Control Board	654873B-50
ICM Term. Brd.	Input Conditioning Module Terminal Board	733849C-01
OB	Output Board	492655B-04
KDI	Keypad/Display Interface	733785B-01
T1	Transformer: 115/24 Vac	606308B-01
T2	Transformer: 24/18 Vac, Center Tapped	467381B-14
CB1	Circuit Breaker	473573B-08
—	Fuse: MCB Input Power, 2 Amp (Bussman No. GDC-2A)	658220A-01
—	Fuse: MCB Communication Ports, 0.25 Amp	658219A-01
—	PC Communications Cable Kit	0057186802
—	RS-232 Cable Extension Kit	0065487001
—	Ribbon Cable Assembly: MCB to Output Board	492652B-07
—	Ribbon Cable Assembly: MCB to Keypad/Display Interface	733665B-01
—	Ribbon Cable Assembly: MCB to ICM Terminal Board Analog Input	733758B-02
—	Ribbon Cable Assembly: MCB to ICM Terminal Board Digital Input	733758B-01
—	Ribbon Cable Assembly (9"): MCB to AOX-4	654997B-02
—	Ribbon Cable Assembly (3"): AOX-4 to AOX-4	654997B-06
—	Modem Kit	0072140601
ICM	Input Conditioning Module	0055323601
AOX-4	Analog Output Expansion Module	0055323701
SSR	Solid-State Relay Kit	0055323901
—	Solid-State Relay (AC)	0049265601
—	Solid-State Relay (DC)	0049265602
—	Dry Contact Relay	0049265603

Notes:

1. If desired, the factory can download the correct software into the replacement MCB prior to shipment. See the "MCB Replacement" section above for more information.